

## **ADDENDUM #2**

**Date:** October 13, 2017

**Project:** Mid-Columbia Center for Living  
1040 Webber Street  
The Dalles, Oregon 97058

**Architect:** **Scott | Edwards Architecture, LLP**  
2525 West Burnside Street  
Portland, OR 97214  
Phone: (503) 226-3617  
Fax: (503) 226-3715

The following list of items shall be incorporated into the contract documents as an addendum issued prior to execution of the contract per AIA Document 201, General Conditions of the Contract for Construction, section 1.1.1:

### **CLARIFICATIONS:**

1. L1.01 LANDSCAPE MATERIAL AND PLANTING PLAN: Maintenance Edge occurs around building perimeter where adjacent to planting areas.
2. All card reader locations shown on Architectural Interior Elevations to be confirmed with hardware schedule per Interior Elevation General Note K. Both base-bid and Alternate work may be shown on elevations.

### **PROJECT MANUAL:**

#### **07 54 23 SINGLE-PLY ROOFING: TPO**

1. Add 2.2.B.3 as follows "R-20 Continuous Insulation or U 0.048.

#### **08 71 00 FINISH HARDWARE**

1. HW SET 02-03: Remove Door 262A. Add Door 262B.
2. HW SET 08-01: Remove Door 262B. Add Door 262A.
3. Add HW SET 02-03A per attached.
4. Revise Hardware Sets 01-01, 01-08, 01-05, 02-06, and 03-04 per attached.
5. Door Hardware Index: Remove from specification in its entirety.

**GENERAL DRAWINGS:**

**G0.01 PROJECT INFORMATION**

1. Alterante # 8: Revise list of doors to include 145, 146, 148, and 262A. Remove Door 262B.

**LANDSCAPE DRAWINGS:**

**L2.00 DETAILS**

1. Revise Detail 06 per attached L2.00, re-issued in its entirety
2. Revise Detail 04 per attached L2.00, re-issued in its entirety.

**ARCHITECTURAL DRAWINGS:**

**A2.02 SECOND FLOOR PLAN**

1. General Sheet Note – Floor Plans: Note D to read “Acoustic Insulation where indicated to extend full height of wall to underside of floor above.”

**A8.02 INTERIOR ELEVATIONS**

1. Elevation 24: Add Card Reader to west of Door 121A

**A8.06 INTERIOR ELEVATIONS**

1. Elevation 10: Add text “CR” at rectangle adjacent to Door 210A.
2. Elevation 11: Add Card Reader at southside of Door 203.

**A8.07 INTERIOR ELEVATIONS**

1. Elevation 23: Relocate southern-most card reader to be adjacent to Door 269.
2. Elevation 25: Delete Card Reader at left edge of elevation.

**A8.08 INTERIOR ELEVATIONS**

1. Add Card Reader adjacent to Door 268.

**A8.09 INTERIOR ELEVATIONS**

1. Elevation 22: Add Card Reader adjacent to Door 284.

**A10.01 DOOR SCHEDULE AND DOOR TYPES**

1. Door 262A: Revise hardware group to 08-01
2. Door 262B: Revise hardware group to 02-03
3. Doors 145,146, and 148: Revise hardware group to 02-03A.

**SUBSTITUTION REQUESTS:**

07 42 13	MTL-1: TBC-ULTRA 12"-16"-18"	Not Accepted. Product does not meet design requirement for 10" wide panel.
07 42 13	MTL-4: 7.2 Rib by TBC	Accepted
07 54 23	Mulehide TPO Roofing Assembly with all components.	Accepted
23 05 48	Vibro-Acoustics Vibration and Seismic Controls Vibration Isolation and Restraint Systems	Accepted
23 36 00	Tuttle and Bailey Model SDV	Accepted with exceptions noted: Coordinate unit "hand" (RH/LH) configuration with floor plans
23 81 26 2.1A	Fujitsu 24 RLXFW High Wall Split System	Accepted
23 09 00 2.1	Daikin Applied "Intelligent Systems" Building Controls for VAV Controls	Not Accepted
27 41 16 2.1.F.1	Electrovoice model PA 1250T	Accepted
27 41.16 2.1.G.1	Soundtube model CM400i-WH	Accepted
27 41 16	Zone Paging Controller: Bogen PCM 2000 + PCMZPM	Accepted
28.10.00	DMP XR550	Accepted
28 10 00 2.1J	DSC Maxsys or NEO	Accepted
26 51 00	A: Lumax AIRLED-29-4K-22-9HR	Accepted
26 51 00	A: Litecontrol LHFL-X-D22-SOF-C1-4000-D28-D10-UNV	Accepted
26 51 00	A1: Lumax AIRLED-29-4K-14-9HR	Accepted
26 51 00	A1: LHFL-X-D14-SOH-C1-4000-D28-D10-UNV	Accepted
26 51 00	B: Brownlee 5178-48-BN-H32LED-40K	Accepted
26 51 00	B: Bartcp Lighting BLT R210-45-40-DM-5-SM	Accepted
26 51 00	B1: Birchwood COL-LED-325-1DR-1IN-CLO-180-40-4-MW-FW-120-D10-WM	Accepted
26 51 00	B1: Neoray S123DIW	Accepted
26 51 00	B2: Elcast 5006-C-LED-120-**	Not Accepted
26 51 00	B2: Lightway ACJW-24-LEW-U-21W-4-FINISH-WSA-DIM	Not Accepted
26 51 00	B2: Eclipse Lighting AP-FB-XL1-LED-4K-EBU-XX-QQT B	Not Accepted
26 51 00	D: Maxilume LED HH6-LED-1500L-DIM10-120-MD-40K-85/HH6-6501-SHZ-SHZ	Accepted

26 51 00	D: Vantage Lighting A8VEFLEDU1140K/L6011FRSGC	Accepted
26 51 00	D2: Kirlin Co. MMR-06705-1000L-120-41K	Accepted
26 51 00	D2: Vantage Lighting A6VOFLEDU1540K/M6060SGC (6" LED housing high efficacy LED with 0-10V dimming	Accepted
26 51 00	F: Prudential Lighting STSQR-LED-LO-R_ - D1-NU-SC-UNV-CA	Not Accepted
26 51 00	G: Birchwood JAK-LED-500-TL-CLO-160-40- 4'-FW-120-D10	Accepted
26 51 00	G: Focal Point FSM6L-FL-875LF-40K-1C- UNV-LD1	Accepted
26 51 00	G1: Birchwood JAK-LED-325-TL-CLO-140-40- 4'-FW-120-D10	Accepted
26 51 00	G1: Focal Point FSM6L-FL-625LF-40K-1C- UNV-LD1	Accepted
26 51 00	G2: Birchwood JAK-LED-325-TL-HLO-40-40- 4'-FW-120-D10	Accepted
26 51 00	G2: Neoray S123DR-140-FES-XXX-1-UDD-1- W	Accepted
26 51 00	J: Oracle LED 4-ASI5-LED-4000L-DIM10- MVOLT-40K-80-**	Accepted with conditions noted: setting of maximum lumen output to be nominal 3,000 lumens
26 51 00	J: Alera LP7-0A-X-40VW-20-CM48-EDU-MW	Accepted
26 51 00	M: Metalux 4SNLED-LD5-30SL-LW-UNV- L840-CD1-U	Accepted
26 51 00	P: Beta Calco 95 0110-30-S1-WH-PR1 (Custom to 4400 Lumens at 44 Watts)	Accepted
26 51 00	P: Kuzco Lighting PD22735-BS	Accepted
26 51 00	SA: HE Williams VA1-L83-740-T3-F-S-XX (L44-4400L)-DIM-UNV	Not Accepted
26 51 00	SA: General Structures CPS-4-4011-20- FINISH-D1	Not Accepted
26 51 00	SA: AV Poles and Lighting AVPL-RMW-TYPE III-36W-120-277-1-4000K	Not Accepted
26 51 00	SA-POLE: AV Poles and Lighting RSS 205- 11	Not Accepted
26 51 00	SA1: HE Williams (2)VA1-L83-740-T3-F- D180-XX (L44-4400L)-DIM-UNV	Not Accepted
26 51 00	SA1-POLE: AV Poles and Lighting RSS 205- 11	Not Accepted
26 51 00	SA1: General Structures CPS-4-4011-20- FINISH-D2	Not Accepted

26 51 00	SC: Maxilume LED HE6-LED-3000L-DIM10-120-MD-40K-85/HH6-6501-SHZ-SHZ	Accepted
26 51 00	SC: Vantage Lighting A6	Accepted
26 51 00	SD: HE Williams VWPV-L30/740-T3-XXX-DIM-UNV	Accepted
26 51 00	SD: Hubbell Outdoor TRP1-12L-30-47K-2-DB	Accepted
26 51 00	X: Emergi-lite WW-TX-1-R	Accepted with conditions noted: Must be green LED color
26 51 00	X: Sure-Lites CX61WH	Accepted
26 51 00	X: Mule Lighting ARS-A-1-G-WW	Accepted
26 51 00	X1: Emergi-lit WW-TX-2-R	Accepted with conditions noted: Must be green LED color
26 51 00	X1; Sure-Lites CS62WH	Accepted
26 51 00	X1: Mule Lighting ARS-A-2-G-WW	Accepted

**ATTACHMENTS:**

**08 71 00 Hardware Sets**

**Drawings:**  
**Full Size: L2.00**

END OF ADDENDUM #2

**HW SET: 01-01****DOOR NUMBER:**100A**EACH TO HAVE:**

<u>QTY</u>	<u>EA</u>	<u>DESCRIPTION</u>	<u>CATALOG NUMBER</u>	<u>FINISH</u>	<u>MFR</u>
<u>2</u>	<u>EA</u>	<u>PIVOT SET</u>	<u>7226 SET</u>	<u>626</u>	<u>IVE</u>
<u>2</u>	<u>EA</u>	<u>INTERMEDIATE PIVOT</u>	<u>7226 INT</u>	<u>626</u>	<u>IVE</u>
<u>2</u>	<u>EA</u>	<u>POWER TRANSFER</u>	<u>EPT10 CON</u>	<u>689</u>	<u>VON</u>
<u>1</u>	<u>EA</u>	<u>ELEC PANIC</u>	<u>RX-EL-25-C-C-ER12-718-CON</u>	<u>630</u>	<u>FAL</u>
		<u>HARDWARE</u>			
<u>1</u>	<u>EA</u>	<u>ELEC PANIC</u>	<u>RX-EL-25-C-EO-ER12-CON</u>	<u>630</u>	<u>FAL</u>
		<u>HARDWARE</u>			
<u>1</u>	<u>EA</u>	<u>MORTISE CYLINDER</u>	<u>20-061-ICX</u>	<u>626</u>	<u>SCH</u>
<u>1</u>	<u>EA</u>	<u>FSIC CORE-1 BITTED</u>	<u>23-030</u>	<u>626</u>	<u>SCH</u>
		<u>"E" KEYWAY</u>			
<u>2</u>	<u>EA</u>	<u>DOOR PULL, 1" ROUND</u>	<u>8190EZHD 12" O</u>	<u>630-316</u>	<u>IVE</u>
<u>1</u>	<u>EA</u>	<u>SURFACE CLOSER</u>	<u>4050 SCUSH</u>	<u>689</u>	<u>LCN</u>
<u>1</u>	<u>EA</u>	<u>SURF. AUTO</u>	<u>4642 WMS</u>	<u>689</u>	<u>LCN</u>
		<u>OPERATOR</u>			
<u>1</u>	<u>EA</u>	<u>CUSH SHOE SUPPORT</u>	<u>4050-30</u>	<u>689</u>	<u>LCN</u>
<u>1</u>	<u>EA</u>	<u>BLADE STOP SPACER</u>	<u>4050-61</u>	<u>689</u>	<u>LCN</u>
<u>1</u>	<u>EA</u>	<u>WEATHER RING</u>	<u>8310-801</u>	<u>PLA</u>	<u>LCN</u>
<u>2</u>	<u>EA</u>	<u>ACTUATOR, WALL</u>	<u>8310-853T</u>	<u>630</u>	<u>LCN</u>
		<u>MOUNT</u>			
<u>2</u>	<u>EA</u>	<u>SURFACE MOUNT BOX</u>	<u>8310-867S</u>	<u>689</u>	<u>LCN</u>
<u>1</u>	<u>EA</u>	<u>WALL STOP</u>	<u>WS406/407CVX</u>	<u>630</u>	<u>IVE</u>
<u>2</u>	<u>EA</u>	<u>DOOR SWEEP</u>	<u>8198AA</u>	<u>AA</u>	<u>ZER</u>
<u>1</u>	<u>EA</u>	<u>THRESHOLD</u>	<u>103A-MSLA-10</u>	<u>A</u>	<u>ZER</u>
<u>1</u>	<u>EA</u>	<u>POWER SUPPLY</u>	<u>PS914 900-BBK 900-4RL</u>	<u>LGR</u>	<u>VON</u>
		<u>ACCESS CONTROL - WORK OF</u>			
		<u>DIVISION 28</u>			
		<u>PROVIDE FACTORY POINT TO POINT</u>			
		<u>WIRING DIAGRAMS</u>			
		<u>PROVIDE FACTORY POINT TO POINT</u>			
		<u>WIRING DIAGRAMS</u>			
		<u>PROVIDE RISER DIAGRAMS</u>			
		<u>WEATHERSTRIP BY DOOR/FRAME</u>			
		<u>MANUFACTURER</u>			

NOTE: 120VAC TO POWER SUPPLY AND ADA OPERATOR. RUN 12 GA WIRE (HOME RUN 0-200 LINEAL FEET) TO EL DEVICES.

**HW SET: 01-02****DOOR NUMBER:**100C**EACH TO HAVE:**

<u>QTY</u>	<u>EA</u>	<u>DESCRIPTION</u>	<u>CATALOG NUMBER</u>	<u>FINISH</u>	<u>MFR</u>
<u>1</u>	<u>EA</u>	<u>PIVOT SET</u>	<u>7226 SET</u>	<u>626</u>	<u>IVE</u>
<u>1</u>	<u>EA</u>	<u>INTERMEDIATE PIVOT</u>	<u>7226 INT</u>	<u>626</u>	<u>IVE</u>
<u>1</u>	<u>EA</u>	<u>PANIC HARDWARE</u>	<u>LD-25-R-NL-OP</u>	<u>630</u>	<u>FAL</u>
<u>1</u>	<u>EA</u>	<u>MORTISE CYLINDER</u>	<u>20-061-ICX</u>	<u>626</u>	<u>SCH</u>

2017-10-13

MID COLUMBIA

08 71 00

1	EA	FSIC CORE-1 BITTED "E" KEYWAY	23-030	626	SCH
1	EA	ELECTRIC STRIKE	6111 FSE 24VDC SHIM CON	630	VON
1	EA	DOOR PULL, 1" ROUND	8190EZHD 12" O	630-316	IVE
2	EA	SURF. AUTO OPERATOR	4642 WMS	689	LCN
2	EA	ACTUATOR, WALL MOUNT	8310-853T	630	LCN
2	EA	SURFACE MOUNT BOX	8310-867S	689	LCN
1	EA	WALL STOP	WS406/407CVX	630	IVE
1	EA	KEY SWITCH	653-04 L2	630	SCE
			PERIMETER SEALS BY DOOR/FRAME MANUFACTURER		
			PROVIDE FACTORY POINT TO POINT WIRING DIAGRAMS		
			PROVIDE RISER DIAGRAMS		

NOTE: 120VAC TO DOOR OPERATOR. KEY SWITCH ENABLES/DISABLES ADA OPERATOR.

**HW SET: 01-03**

DOOR NUMBER:

140B

EACH TO HAVE:

<u>QTY</u>		<u>DESCRIPTION</u>	<u>CATALOG NUMBER</u>	<u>FINISH</u>	<u>MFR</u>
3	EA	HW HINGE	5BB1HW 4.5 X 4.5 NRP	652	IVE
1	EA	FIRE EXIT HARDWARE	F-25-R-L-DANE	630	FAL
1	EA	MORTISE CYLINDER	20-061-ICX	626	SCH
1	EA	FSIC CORE-1 BITTED "E" KEYWAY	23-030	626	SCH
1	EA	ELECTRIC STRIKE	6111 FSE 24VDC CON	630	VON
1	EA	SURF. AUTO OPERATOR	4631 WMS	689	LCN
2	EA	ACTUATOR, WALL MOUNT	8310-853T	630	LCN
2	EA	SURFACE MOUNT BOX	8310-867S	689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B-CS	630	IVE
1	EA	WALL STOP	WS406/407CVX	630	IVE
1	EA	GASKETING	188S-BK	S-BK	ZER
1	EA	KEY SWITCH	653-04 L2	630	SCE
			PROVIDE FACTORY POINT TO POINT WIRING DIAGRAMS		
			PROVIDE RISER DIAGRAMS		

NOTE: 120VAC TO DOOR OPERATOR. CONNECT ADA OPERATOR TO FIRE ALARM. ADA OPERATOR TO BECOME INOPERATIVE DURING FIRE ALARM ACTIVATION. KEY SWITCH ENABLES/DISABLES ADA OPERATOR.

**HW SET: 01-04**

DOOR NUMBER:

105A

106A

107A

## EACH TO HAVE:

<u>QTY</u>		<u>DESCRIPTION</u>	<u>CATALOG NUMBER</u>	<u>FINISH</u>	<u>MFR</u>
3	EA	HW HINGE	5BB1HW 4.5 X 4.5 NRP	652	IVE
1	EA	PANIC HARDWARE	25-R-L-DANE	630	FAL
1	EA	MORTISE CYLINDER	20-061-ICX	626	SCH
1	EA	FSIC CORE-1 BITTED "E" KEYWAY	23-030	626	SCH
1	EA	ELECTRIC STRIKE	6111 FSE 24VDC CON (ALTERNATE #8. FUTURE CARD READER. CHANGE TO ELECTRIC STRIKE)	630	VON
1	EA	SURFACE CLOSER	4050 EDA	689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B-CS	630	IVE
1	EA	WALL STOP	WS406/407CVX	630	IVE
3	EA	SILENCER	SR64	GRY	IVE

**HW SET: 01-05****DOOR NUMBER:**

105B                      106B                      107B

## EACH TO HAVE:

<u>QTY</u>		<u>DESCRIPTION</u>	<u>CATALOG NUMBER</u>	<u>FINISH</u>	<u>MFR</u>
<u>1</u>	<u>EA</u>	<u>PIVOT SET</u>	<u>7226 SET</u>	<u>626</u>	<u>IVE</u>
<u>1</u>	<u>EA</u>	<u>INTERMEDIATE PIVOT</u>	<u>7226 INT</u>	<u>626</u>	<u>IVE</u>
<u>1</u>	<u>EA</u>	<u>PANIC HARDWARE</u>	<u>LD-25-R-NL-OP</u>	<u>630</u>	<u>FAL</u>
<u>1</u>	<u>EA</u>	<u>MORTISE CYLINDER</u>	<u>20-061-ICX</u>	<u>626</u>	<u>SCH</u>
<u>1</u>	<u>EA</u>	<u>FSIC CORE-1 BITTED "E" KEYWAY</u>	<u>23-030</u>	<u>626</u>	<u>SCH</u>
<u>1</u>	<u>EA</u>	<u>ELECTRIC STRIKE</u>	<u>6111 FSE 24VDC SHIM CON</u>	<u>630</u>	<u>VON</u>
<u>1</u>	<u>EA</u>	<u>DOOR PULL, 1" ROUND</u>	<u>8190EZHD 12" O</u>	<u>630-316</u>	<u>IVE</u>
<u>1</u>	<u>EA</u>	<u>OH STOP</u>	<u>100S ADJ</u>	<u>630</u>	<u>GLY</u>
<u>1</u>	<u>EA</u>	<u>SURFACE CLOSER</u>	<u>4050 EDA</u>	<u>689</u>	<u>LCN</u>
<u>1</u>	<u>EA</u>	<u>BLADE STOP SPACER</u>	<u>4050-61</u>	<u>689</u>	<u>LCN</u>
<u>1</u>	<u>EA</u>	<u>DOOR SWEEP</u>	<u>8198AA</u>	<u>AA</u>	<u>ZER</u>
<u>1</u>	<u>EA</u>	<u>THRESHOLD</u>	<u>103A-MSLA-10</u>	<u>A</u>	<u>ZER</u>
<u>1</u>	<u>EA</u>	<u>RAIN DRIP</u>	<u>142A</u>	<u>A</u>	<u>ZER</u>
<u>1</u>	<u>EA</u>	<u>MOTION SENSOR</u>	<u>SCANII</u>	<u>WHT</u>	<u>SCE</u>
			<u>ACCESS CONTROL - WORK OF</u>		
			<u>DIVISION 28</u>		
			<u>POWER SUPPLY - WORK OF DIVISION</u>		
			<u>28</u>		
			<u>WEATHERSTRIP BY DOOR/FRAME</u>		
			<u>MANUFACTURER</u>		

**HW SET: 01-06****DOOR NUMBER:**

149

## EACH TO HAVE:

<u>QTY</u>		<u>DESCRIPTION</u>	<u>CATALOG NUMBER</u>	<u>FINISH</u>	<u>MFR</u>
3	EA	HW HINGE	5BB1HW 4.5 X 4.5 NRP	652	IVE
1	EA	PANIC HARDWARE	LD-25-R-L-NL-DANE	630	FAL



2017-10-13

MID COLUMBIA

08 71 00

1	EA	MORTISE CYLINDER	20-061-ICX	626	SCH
1	EA	FSIC CORE-1 BITTED "E" KEYWAY	23-030	626	SCH
1	EA	ELECTRIC STRIKE	6111 FSE 24VDC CON	630	VON
1	EA	SURFACE CLOSER	4050 CUSH	689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B-CS	630	IVE
3	EA	SILENCER	SR64	GRY	IVE
1	EA	MOTION SENSOR	SCANII	WHT	SCE
			ACCESS CONTROL - WORK OF DIVISION 28		
			POWER SUPPLY - WORK OF DIVISION 28		

**HW SET: 01-07**

DOOR NUMBER:

260

EACH TO HAVE:

<u>QTY</u>		<u>DESCRIPTION</u>	<u>CATALOG NUMBER</u>	<u>FINISH</u>	<u>MFR</u>
3	EA	HW HINGE	5BB1HW 4.5 X 4.5 NRP	652	IVE
1	EA	FIRE EXIT HARDWARE	F-25-R-L-BE-DANE-SNB	630	FAL
1	EA	SURFACE CLOSER	4050T	689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B-CS	630	IVE
1	EA	WALL STOP	WS406/407CVX	630	IVE
1	EA	GASKETING	188S-BK	S-BK	ZER

NOTE: 120VAC TO POWER SUPPLY. RUN 18 AWG MINIMUM WIRE FROM POWER SUPPLY TO E996 ELECTRIFIED TRIM. CONNECT FIRE ALARM CONTACTS IN POWER SUPPLY TO FIRE ALARM. ACCESS CONTROLLED FROM STAIR SIDE. FAIL SAFE LEVER TRIM RELEASES ON ACCESS CONTROL, FIRE ALARM ACTIVATION, OR POWER FAILURE.

**HW SET: 01-08**

DOOR NUMBER:

100B

EACH TO HAVE:

<u>QTY</u>		<u>DESCRIPTION</u>	<u>CATALOG NUMBER</u>	<u>FINISH</u>	<u>MFR</u>
1	EA	PIVOT SET	7226 SET	626	IVE
1	EA	INTERMEDIATE PIVOT	7226 INT	626	IVE
1	EA	PANIC HARDWARE	LD-25-R-NL-OP	630	FAL
1	EA	MORTISE CYLINDER	20-061-ICX	626	SCH
1	EA	FSIC CORE-1 BITTED "E" KEYWAY	23-030	626	SCH
1	EA	ELECTRIC STRIKE	6111 FSE 24VDC SHIM CON	630	VON
1	EA	DOOR PULL, 1" ROUND	8190EZHD 12" O	630-316	IVE
1	EA	SURFACE CLOSER	4050 EDA	689	LCN
1	EA	BLADE STOP SPACER	4050-61	689	LCN
1	EA	WALL STOP	WS406/407CVX	630	IVE
1	EA	MOTION SENSOR	SCANII	WHT	SCE
			ACCESS CONTROL - WORK OF DIVISION 28		

PERIMETER SEALS BY DOOR/FRAME  
MANUFACTURER  
POWER SUPPLY - WORK OF DIVISION  
28

**HW SET: 01-09**

DOOR NUMBER:

140A                    S2B

EACH TO HAVE:

<u>QTY</u>		<u>DESCRIPTION</u>	<u>CATALOG NUMBER</u>	<u>FINISH</u>	<u>MFR</u>
1	EA	PIVOT SET	7226 SET	626	IVE
1	EA	INTERMEDIATE PIVOT	7226 INT	626	IVE
1	EA	PANIC HARDWARE	LD-25-R-NL-OP	630	FAL
1	EA	MORTISE CYLINDER	20-061-ICX	626	SCH
1	EA	FSIC CORE-1 BITTED "E" KEYWAY	23-030	626	SCH
1	EA	ELECTRIC STRIKE	6111 FSE 24VDC SHIM CON	630	VON
1	EA	DOOR PULL, 1" ROUND	8190EZHD 12" O	630-316	IVE
1	EA	OH STOP	100S ADJ	630	GLY
1	EA	SURF. AUTO OPERATOR	4642 WMS	689	LCN
1	EA	WEATHER RING	8310-801	PLA	LCN
2	EA	ACTUATOR, WALL MOUNT	8310-853T	630	LCN
2	EA	SURFACE MOUNT BOX	8310-867S	689	LCN
1	EA	DOOR SWEEP	8198AA	AA	ZER
1	EA	THRESHOLD	103A-MSLA-10	A	ZER
1	EA	RAIN DRIP	142A	A	ZER
1	EA	KEY SWITCH	653-04 L2	630	SCE

PROVIDE FACTORY POINT TO POINT  
WIRING DIAGRAMS  
PROVIDE RISER DIAGRAMS  
WEATHERSTRIP BY DOOR/FRAME  
MANUFACTURER

NOTE: 120VAC TO DOOR OPERATOR. KEY SWITCH ENABLES/DISABLES ADA OPERATOR.

**HW SET: 01-10**

DOOR NUMBER:

110                    130

EACH TO HAVE:

<u>QTY</u>		<u>DESCRIPTION</u>	<u>CATALOG NUMBER</u>	<u>FINISH</u>	<u>MFR</u>
3	EA	HW HINGE	5BB1HW 4.5 X 4.5 NRP	652	IVE
1	EA	PANIC HARDWARE	LD-25-R-L-NL-DANE	630	FAL
1	EA	MORTISE CYLINDER	20-061-ICX	626	SCH
1	EA	FSIC CORE-1 BITTED "E" KEYWAY	23-030	626	SCH
1	EA	ELECTRIC STRIKE	6111 FSE 24VDC CON	630	VON
1	EA	SURFACE CLOSER	4050 EDA	689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B-CS	630	IVE

2017-10-13

MID COLUMBIA

08 71 00

1	EA	WALL STOP	WS406/407CVX	630	IVE
3	EA	SILENCER	SR64	GRY	IVE
1	EA	MOTION SENSOR	SCANII	WHT	SCE
ACCESS CONTROL - WORK OF DIVISION 28					
POWER SUPPLY - WORK OF DIVISION 28					

**HW SET: 02-01**

DOOR NUMBER:  
101A

EACH TO HAVE:

<u>QTY</u>		<u>DESCRIPTION</u>	<u>CATALOG NUMBER</u>	<u>FINISH</u>	<u>MFR</u>
6	EA	HINGE	5BB1 4.5 X 4.5 NRP	652	IVE
2	EA	MANUAL FLUSH BOLT	FB458	626	IVE
1	EA	DUST PROOF STRIKE	DP2	626	IVE
1	EA	STOREROOM LOCK	ND80PD RHO	626	SCH
2	EA	OH STOP	90S	630	GLY
1	EA	ASTRAGAL	41AA	AA	ZER
4	EA	SILENCER	SR64	GRY	IVE

**HW SET: 02-02**

DOOR NUMBER:  
103                    108B                    115                    144                    264

EACH TO HAVE:

<u>QTY</u>		<u>DESCRIPTION</u>	<u>CATALOG NUMBER</u>	<u>FINISH</u>	<u>MFR</u>
3	EA	HINGE	5BB1 4.5 X 4.5 NRP	652	IVE
1	EA	STOREROOM LOCK	ND80PD RHO	626	SCH
1	EA	ELECTRIC STRIKE	6211 FSE 24VDC CON	630	VON
1	EA	LOCK GUARD	LG14	630	IVE
1	EA	SURFACE CLOSER	4050 SCUSH	689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B-CS	630	IVE
3	EA	SILENCER	SR64	GRY	IVE
1	EA	MOTION SENSOR	SCANII	WHT	SCE
ACCESS CONTROL - WORK OF DIVISION 28					
POWER SUPPLY - WORK OF DIVISION 28					

**HW SET: 02-03**

DOOR NUMBER:

108A	109	111	123	124	125
131	132	445	446	448	206A
210A	220	230	<del>262A</del>	<u>262B</u>	

EACH TO HAVE:

<u>QTY</u>		<u>DESCRIPTION</u>	<u>CATALOG NUMBER</u>	<u>FINISH</u>	<u>MFR</u>
------------	--	--------------------	-----------------------	---------------	------------

3	EA	HINGE	5BB1 4.5 X 4.5 NRP	652	IVE
1	EA	STOREROOM LOCK	ND80PD RHO	626	SCH
1	EA	ELECTRIC STRIKE	6211 FSE 24VDC CON	630	VON
1	EA	SURFACE CLOSER	4050T	689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B-CS	630	IVE
1	EA	WALL STOP	WS406/407CVX	630	IVE
3	EA	SILENCER	SR64	GRY	IVE
1	EA	MOTION SENSOR	SCANII	WHT	SCE
			ACCESS CONTROL - WORK OF		
			DIVISION 28		
			POWER SUPPLY - WORK OF DIVISION		
			28		

**HW SET: 02-03A**

**DOOR NUMBER:**

145                      146                      148

**EACH TO HAVE:**

<u>QTY</u>		<u>DESCRIPTION</u>	<u>CATALOG NUMBER</u>	<u>FINISH</u>	<u>MFR</u>
<u>3</u>	<u>EA</u>	<u>HINGE</u>	<u>5BB1 4.5 X 4.5 NRP</u>	<u>652</u>	<u>IVE</u>
<u>1</u>	<u>EA</u>	<u>STOREROOM LOCK</u>	<u>ND80PD RHO</u>	<u>626</u>	<u>SCH</u>
<u>1</u>	<u>EA</u>	<u>ELECTRIC STRIKE</u>	<u>6211 FSE 24VDC CON</u>	<u>630</u>	<u>VON</u>
<u>1</u>	<u>EA</u>	<u>KICK PLATE</u>	<u>8400 10" X 2" LDW B-CS</u>	<u>630</u>	<u>IVE</u>
			<u>(AT JANITOR 145 ONLY)</u>		
<u>1</u>	<u>EA</u>	<u>WALL STOP</u>	<u>WS406/407CVX</u>	<u>630</u>	<u>IVE</u>
<u>3</u>	<u>EA</u>	<u>SILENCER</u>	<u>SR64</u>	<u>GRY</u>	<u>IVE</u>

**NOTE: FUTURE CARD READER.**

**HW SET: 02-04**

**DOOR NUMBER:**

113A                      121A                      141                      143                      221                      223  
 242                      261                      263                      265                      267

**EACH TO HAVE:**

<u>QTY</u>		<u>DESCRIPTION</u>	<u>CATALOG NUMBER</u>	<u>FINISH</u>	<u>MFR</u>
3	EA	HINGE	5BB1 4.5 X 4.5 NRP	652	IVE
1	EA	STOREROOM LOCK	ND80PD RHO	626	SCH
1	EA	ELECTRIC STRIKE	6211 FSE 24VDC CON	630	VON
1	EA	OH STOP	90S	630	GLY
1	EA	SURFACE CLOSER	4050T	689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B-CS	630	IVE
3	EA	SILENCER	SR64	GRY	IVE
1	EA	MOTION SENSOR	SCANII	WHT	SCE
			ACCESS CONTROL - WORK OF		
			DIVISION 28		
			POWER SUPPLY - WORK OF DIVISION		
			28		

**HW SET: 02-05**

DOOR NUMBER:

206B                    210B                    240                    250

EACH TO HAVE:

<u>QTY</u>		<u>DESCRIPTION</u>	<u>CATALOG NUMBER</u>	<u>FINISH</u>	<u>MFR</u>
3	EA	HINGE	5BB1 4.5 X 4.5 NRP	652	IVE
1	EA	STOREROOM LOCK	ND80PD RHO	626	SCH
1	EA	ELECTRIC STRIKE	6211 FSE 24VDC CON	630	VON
1	EA	SURFACE CLOSER	4050 EDA	689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B-CS	630	IVE
1	EA	WALL STOP	WS406/407CVX	630	IVE
3	EA	SILENCER	SR64	GRY	IVE
1	EA	MOTION SENSOR	SCANII	WHT	SCE
			ACCESS CONTROL - WORK OF		
			DIVISION 28		
			POWER SUPPLY - WORK OF DIVISION		
			28		

**HW SET: 02-06**

DOOR NUMBER:

140C

EACH TO HAVE:

<u>QTY</u>		<u>DESCRIPTION</u>	<u>CATALOG NUMBER</u>	<u>FINISH</u>	<u>MFR</u>
6	EA	HINGE	5BB1 4.5 X 4.5 NRP	652	IVE
2	EA	MANUAL FLUSH BOLT	FB458	626	IVE
1	EA	DUST PROOF STRIKE	DP2	626	IVE
1	EA	STOREROOM LOCK	ND80PD RHO XQ07-351	626	SCH
1	EA	ELECTRIC STRIKE	6223 FSE CON	630	VON
2	EA	WALL STOP	WS406/407CVX	630	IVE
1	EA	ASTRAGAL	41AA	AA	ZER
4	EA	SILENCER	SR64	GRY	IVE
1	EA	MOTION SENSOR	SCANII	WHT	SCE
			ACCESS CONTROL - WORK OF		
			DIVISION 28		
			POWER SUPPLY - WORK OF DIVISION		
			28		

**HW SET: 02-09**

DOOR NUMBER:

284

EACH TO HAVE:

<u>QTY</u>		<u>DESCRIPTION</u>	<u>CATALOG NUMBER</u>	<u>FINISH</u>	<u>MFR</u>
3	EA	HINGE	5BB1 4.5 X 4.5 NRP	652	IVE
1	EA	STOREROOM LOCK	ND80PD RHO	626	SCH
1	EA	ELECTRIC STRIKE	6211 FSE 24VDC CON	630	VON
			(ALTERNATE #8. FUTURE CARD		
			READER. CHANGE TO ELECTRIC		
			STRIKE)		

2017-10-13

MID COLUMBIA

08 71 00

1	EA	OH STOP	90S	630	GLY
1	EA	KICK PLATE	8400 10" X 2" LDW B-CS	630	IVE
3	EA	SILENCER	SR64	GRY	IVE

**HW SET: 02-10**

DOOR NUMBER:

E1

EACH TO HAVE:

<u>QTY</u>		<u>DESCRIPTION</u>	<u>CATALOG NUMBER</u>	<u>FINISH</u>	<u>MFR</u>
3	EA	HINGE	5BB1 4.5 X 4.5 NRP	652	IVE
1	EA	STOREROOM LOCK	ND80PD RHO	626	SCH
1	EA	ELECTRIC STRIKE	6211 FSE 24VDC CON (ALTERNATE #8. FUTURE CARD READER. CHANGE TO ELECTRIC STRIKE)	630	VON
1	EA	LOCK GUARD	LG14	630	IVE
1	EA	SURFACE CLOSER	4050 EDA	689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B-CS	630	IVE
1	EA	FLOOR STOP	FS436	626	IVE
1	EA	GASKETING	188S-BK	S-BK	ZER

**HW SET: 02-11**

DOOR NUMBER:

160

EACH TO HAVE:

<u>QTY</u>		<u>DESCRIPTION</u>	<u>CATALOG NUMBER</u>	<u>FINISH</u>	<u>MFR</u>
3	EA	HINGE	5BB1 4.5 X 4.5 NRP	652	IVE
1	EA	STOREROOM LOCK	ND80PD RHO	626	SCH
1	EA	ELECTRIC STRIKE	6211 FSE 24VDC CON (ALTERNATE #8. FUTURE CARD READER. CHANGE TO ELECTRIC STRIKE)	630	VON
1	EA	SURFACE CLOSER	4050 RW/PA	689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B-CS	630	IVE
1	EA	WALL STOP	WS406/407CVX	630	IVE
1	EA	GASKETING	188S-BK	S-BK	ZER

**HW SET: 03-01**

DOOR NUMBER:

153                      154                      155                      156

EACH TO HAVE:

<u>QTY</u>		<u>DESCRIPTION</u>	<u>CATALOG NUMBER</u>	<u>FINISH</u>	<u>MFR</u>
3	EA	HINGE	5BB1 4.5 X 4.5 NRP	652	IVE
1	EA	PRIVACY WITH OCCUPIED INDICATOR	L9456T 06A L583-363 L283-722	626	SCH

2017-10-13

MID COLUMBIA

08 71 00

1	EA	FSIC CORE-1 BITTED "E" KEYWAY	23-030	626	SCH
1	EA	WALL STOP	WS406/407CVX	630	IVE
1	EA	GASKETING	188S-BK	S-BK	ZER

**HW SET: 03-02**

DOOR NUMBER:

133	205	208	209	281	282
-----	-----	-----	-----	-----	-----

EACH TO HAVE:

<u>QTY</u>		<u>DESCRIPTION</u>	<u>CATALOG NUMBER</u>	<u>FINISH</u>	<u>MFR</u>
3	EA	HINGE	5BB1 4.5 X 4.5 NRP	652	IVE
1	EA	PRIVACY WITH OCCUPIED INDICATOR	L9456T 06A L583-363 L283-722	626	SCH
1	EA	FSIC CORE-1 BITTED "E" KEYWAY	23-030	626	SCH
1	EA	SURFACE CLOSER	4050T	689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B-CS	630	IVE
1	EA	WALL STOP	WS406/407CVX	630	IVE
1	EA	GASKETING	188S-BK	S-BK	ZER

**HW SET: 03-03**

DOOR NUMBER:

152

EACH TO HAVE:

<u>QTY</u>		<u>DESCRIPTION</u>	<u>CATALOG NUMBER</u>	<u>FINISH</u>	<u>MFR</u>
3	EA	HINGE	5BB1 4.5 X 4.5 NRP	652	IVE
1	EA	PRIVACY WITH OCCUPIED INDICATOR	L9456T 06A L583-363 L283-722	626	SCH
1	EA	FSIC CORE-1 BITTED "E" KEYWAY	23-030	626	SCH
1	EA	OH STOP	90S	630	GLY
1	EA	GASKETING	188S-BK	S-BK	ZER

**HW SET: 03-04**

DOOR NUMBER:

283

EACH TO HAVE:

<u>QTY</u>		<u>DESCRIPTION</u>	<u>CATALOG NUMBER</u>	<u>FINISH</u>	<u>MFR</u>
3	EA	HINGE	5BB1 4.5 X 4.5 NRP	652	IVE
1	EA	PRIVACY WITH OCCUPIED INDICATOR	L9456T 06A L583-363 L283-722	626	SCH
1	EA	FSIC CORE-1 BITTED "E" KEYWAY	23-030	626	SCH
1	EA	SURFACE CLOSER	4050T	689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B-CS	630	IVE
1	EA	WALL STOP	WS406/407CVX	630	IVE

1    EA    GASKETING                      188S-BK                      S-BK            ZER

**HW SET: 04-01**

DOOR NUMBER:

116                      117

EACH TO HAVE:

<u>QTY</u>		<u>DESCRIPTION</u>	<u>CATALOG NUMBER</u>	<u>FINISH</u>	<u>MFR</u>
3	EA	HINGE	5BB1 4.5 X 4.5 NRP	652	IVE
1	EA	PUSH PLATE	8200 4" X 16"	630	IVE
1	EA	PULL PLATE	8302 6" 4" X 16" G	630	IVE
1	EA	SURFACE CLOSER	4050T	689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B-CS	630	IVE
1	EA	WALL STOP	WS406/407CVX	630	IVE
3	EA	SILENCER	SR64	GRY	IVE

**HW SET: 05-01**

DOOR NUMBER:

121B

EACH TO HAVE:

<u>QTY</u>		<u>DESCRIPTION</u>	<u>CATALOG NUMBER</u>	<u>FINISH</u>	<u>MFR</u>
1	SET	3-DR STACKING POCKET DOOR ASSEMBLY	200MP (FOR 1-3/4" DOORS)	Z	JOH
1	EA	SLIDING DOOR LOCK	2002 CPDL-1 KEYED CYLINDER ONE SIDE	630	ACC
1	EA	FLUSH PULL	S2002B X 1-3/4" DOOR	630	ACC
1	EA	FLUSH PULL WITH CYLINDER HOLE	S2002C X 1-3/4" DOOR	630	ACC
1	EA	MORTISE CYLINDER	20-061-ICX	626	SCH
1	EA	FSIC CORE-1 BITTED "E" KEYWAY	23-030	626	SCH

**HW SET: 06-01**

DOOR NUMBER:

112

EACH TO HAVE:

<u>QTY</u>		<u>DESCRIPTION</u>	<u>CATALOG NUMBER</u>	<u>FINISH</u>	<u>MFR</u>
3	EA	HINGE	5BB1 4.5 X 4.5 NRP	652	IVE
1	EA	CLASSROOM LOCK	ND70PD RHO	626	SCH
1	EA	ELECTRIC STRIKE	6211 FSE 24VDC CON (ALTERNATE #8. FUTURE CARD READER. CHANGE TO ELECTRIC STRIKE)	630	VON
1	EA	OH STOP	90S	630	GLY
3	EA	SILENCER	SR64	GRY	IVE



**HW SET: 06-02**

DOOR NUMBER:

142	203	241	243	245	266
268	269	270			

EACH TO HAVE:

<u>QTY</u>		<u>DESCRIPTION</u>	<u>CATALOG NUMBER</u>	<u>FINISH</u>	<u>MFR</u>
3	EA	HINGE	5BB1 4.5 X 4.5 NRP	652	IVE
1	EA	CLASSROOM LOCK	ND70PD RHO	626	SCH
1	EA	ELECTRIC STRIKE	6211 FSE 24VDC CON (ALTERNATE #8. FUTURE CARD READER. CHANGE TO ELECTRIC STRIKE)	630	VON
1	EA	WALL STOP	WS406/407CVX	630	IVE
3	EA	SILENCER	SR64	GRY	IVE

**HW SET: 07-01**

DOOR NUMBER:

TIME OUT

EACH TO HAVE:

<u>QTY</u>		<u>DESCRIPTION</u>	<u>CATALOG NUMBER</u>	<u>FINISH</u>	<u>MFR</u>
2	EA	HW HINGE	5BB1HW 5 X 4.5 NRP	652	IVE
1	EA	CYLINDER FLUSH BOLT-WOOD DOORS	1877	626	ADA
1	EA	DUST PROOF STRIKE	DP2	626	IVE
1	EA	THUMB TURN CYLINDER	4066	628	ADA
1	EA	WALL STOP	WS406/407CVX	630	IVE

**HW SET: 08-01**

DOOR NUMBER:

211	212	213	214	215	216
231	232	233	234	235	251
252	253	254	255	256	257
<u>262A</u>	<u>262B</u>				

EACH TO HAVE:

<u>QTY</u>		<u>DESCRIPTION</u>	<u>CATALOG NUMBER</u>	<u>FINISH</u>	<u>MFR</u>
3	EA	HINGE	5BB1 4.5 X 4.5 NRP	652	IVE
1	EA	ENTRANCE/OFFICE LOCK	ND50PD RHO	626	SCH
1	EA	ELECTRIC STRIKE	6211 FSE 24VDC CON (ALTERNATE #8. FUTURE CARD READER. CHANGE TO ELECTRIC STRIKE)	630	VON
1	EA	WALL STOP	WS406/407CVX	630	IVE
3	EA	SILENCER	SR64	GRY	IVE