


- SHEET NOTES**
- RADIANT HEATER HAS BEEN SELECTED TO BE 120V POWER CONNECTION.
 - ROUTE 40 VENT TO BUILDING SIDEWALL - TERMINATE WITH MANUFACTURER'S SIDEWALL VENT KIT
 - REMOVE EXISTING WEATHERHOOD AND TRANSITION FROM PARTS WASHER EXISTING EXHAUST VENT TO AN 80 RIGID SPIRAL DUCT - ROUTE VERTICALLY UP WALL AND ACROSS THE NEW ADDITION. MAINTAIN MAXIMUM HEIGHT IN SPACE
 - REMOVE EXISTING EXTERIOR WEATHERHOOD AND CONNECT 140 DUCT TO SHEET METAL WALL SLEEVE - VERIFY SLEEVE AND DUCT SIZE AT THE SITE
 - PROVIDE A MOTORIZED DAMPER TO OPEN ON EXHAUST FAN STARTUP AND CLOSE ON FAN SHUTDOWN - PROVIDE ALL WIRING AND DEVICES FOR A COMPLETE AND OPERATING INSTALLATION
 - CONNECT 80 UNDERGROUND DUCT BRANCHES TO COMMON 80 RISER THROUGH FLOOR - ROUTE RISER UP ADJACENT TO WALL AND CONNECT TO EXHAUST FAN (F-1)
 - CONNECT 80 UNDERGROUND DUCT BRANCHES TO COMMON 80 RISER THROUGH FLOOR - ROUTE RISER UP ADJACENT TO WALL AND CONNECT TO EXHAUST FAN (F-1)
 - PROVIDE AN AUDIO AND VISUAL ALARM FOR THE CO AND NO2 SENSORS

1 SHOP BUILDING FLOOR PLAN



COPYRIGHT 2016
STEELE ASSOCIATES ARCHITECTS, L.L.C.
All rights reserved. Reproduction or use in any form or by any means (graphic, electronic, mechanical, etc.) without written permission of STEELE ASSOCIATES ARCHITECTS, L.L.C. is unlawful and subject to criminal prosecution.

STAMP
REGISTERED PROFESSIONAL ENGINEER
18500
OREGON
JULY 13, 1984
GARY C. BARNES
EXPIRES 12/31/17

STEELE ASSOCIATES
ARCHITECTS LLC
686 NW YORK DRIVE #150
541.382.9867 FAX 541.385.8816 info@steele-arch.com

BEND, OR 97703

BLS - TRANSPORTATION FACILITY 2017
601 SE 2ND STREET BEND, OR

FLOOR PLAN - HVAC-SHOP BUILDING

JOB NO.	16116.01
DATE	7/12/2017
DRAWN BY	KMJ
CHECKED BY	SCB
REVISIONS	DATE
PERMIT SUBMITTAL	07/14/2017

SDC - QUALITY CONTROL	
PROJ. MGR.	
PRODUCTION	
QUAL. CONTROL	
ENGINEER	

SDS SYSTEM DESIGN CONSULTANTS INC.
333 SE SECOND AVE. SUITE 100
PORTLAND OREGON 97214
503-248-0227 FAX 248-0240
CONTACT: KELLY M. JOHNSON

SHEET NO.
M1.25

PERMIT REVIEW SET