

MERCADO GUADALAJARA EXPANSION

Date: 12/18/2020

Project Mercado Guadalajara Expansion
1802 12th Street
Hood River, OR 97031

The following list of items shall be incorporated into the contract documents as an addendum issued prior to execution of contract.

Questions:

- 1 Q What height is the drywall installed throughout the exterior wall of the spaces?
- A Drywall will extend from the ground level to the ceiling.

Drawing Revisions:

Architectural

- G001 Strike structural sheets that aren't part of bid set.
- A011 Revised drive approach to ODOT standards.
- A011 Demo existing light poles at each side of drive.
- A101 Concrete SOG demo extents for trench drain, uneven floors and plumbing drains.
- A120 Add callout for new furring and hardlid at lower ceiling.
- A120 Add note for concrete SOG pourbacks per sheet A101 demo plan.
- A601 Modify table to delete painting at (E) Meat, Cooking, Baking and Storage Area

Substitution Requests: