

Addendum 03

TO	Bidders & Plan Centers				
FROM	Jeff Schott, P.E.				
PROJECT	Sherman County Fair Grounds Arena				
SUBJECT	Addendum 003				
DATE	9/16/2021	PROJECT #	2021-009	MEMO #	PM-04

THIS ADDENDUM DOES NOT CHANGE THE BID TIME & DATE. THE BID TIME AND DATE IS TUESDAY, SEPTEMBER 21, 2021, 2 PM Pacific Time..

Added documents:

N/A

Revised documents:

- 1) Civil drawings C001, C011, C012, C013 C021, C031-C036 revision sequence 2021 09 15. Summary of changes:
 - a) Added gate and signage on pond fence
 - b) Relocated flag pole and show 2-lights
 - c) Clarified grades on pond
 - d) Revised location and connection point to existing irrigation line (reduced total new irrigation pipe. Also clarified location of irrigation pipe to remain in service during construction. Changes detail to pond connection.
 - e) Show (3) added 2" data conduits described in previous addendum
- 2) Pump house drawings A252 revision 1, 2021 09 16: Added details for exhaust fan and inlet louver. No updated electrical or mechanical drawings but will be assumed to be addressed by electrical and mechanical in bid.
- 3) Kitchen drawings FS1.2, revisions 1. Corrects electrical call out on microwave from 15 amp to 20 amp circuit. Electrical drawings not up-dated , but is assumed to be addressed by electrical in bid.

Questions & Clarifications:

- 1) *Did you mean for the Taylor metal roofing to be MS-100 instead of SM100?*
Yes.
- 2) *Addendum 1. This addendum clarified that the fire pump will be a 60hp design which pushes us past the Pacific Power 200 amp service limit, of no larger than a 60hp 208v 3 phase motor maximum, not including other loads. Since this service will also*



Professional Engineering and Project Management

be feeding a jockey pump and other loads, would you like us to bid this as a 400 amp service now (change it from a 200 amp meterbase to a 400 amp CT can with meter)?

No. Bid as 200-amp services. We believe that we will be able to work with the fire pump provider to supply a pump that will be compatible with 200-amp service.

3) *Can you clarify if low voltage wiring is required to be in raceways or is open wiring permitted?*

Exposed low voltage wiring above 8' AFF in the Arena may be exposed for lighting controls. Cables shall be firmly secured to structural element or other conduit on intervals not exceeding 48" o.c. Cables shall be of approved color.

4) See updated plan holder list.

Approved alternates:

- 1) Web-steel building is approved PEMB supplier.
- 2) Pump and expansion tank manufacturer: TACO
- 3) Booster pump manufacturer: Franklin Controls.